

Addendum No. 1  
Issue Date: November 8, 2010

Project Name: Sidewalk Enhancement FY 11  
Project No.: CMAQ1  
CRM BID #: 75991  
Bid Opening November 11, 2010 2:00 PM

**TO: Prospective Bidders**

This addendum forms a part of the Contract Documents and modifies the original Contract Documents dated September 2010 as noted below. Acknowledge receipt of this Addendum by inserting the number and issue date of this addendum in the blank space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum No. # 1 consists of 1 page.

**CLARIFICATIONS:**

1. Use high early strength concrete at all driveways. Bid item for 6" Concrete Driveways (1.18, 2.18, 3.18) is to include work for 6" concrete sidewalk. 6" sidewalk is only anticipated to be required at driveways.
2. Bid item for Concrete Wheelchair Ramps (1.15, 2.15, 3.15) does not include the removal of concrete curb & gutter or the installation of depressed curb. Required curb & gutter removal will be paid for under the bid item for Removal of Existing Concrete, C&G/VG (1.07, 2.07, 3.07). Installation of depressed curb will be paid for under the bid item for 2'-6" Concrete Curb and Gutter (1.14, 2.14, 3.14).
3. Bid item for Incidental Stone Base (1.08, 2.08, 3.08) will include the use of #57, #67 or CABC as specified in CRM Standard Detail 2.20 for the standard sidewalk cross section.
4. Concrete sidewalk is to be constructed per NCDOT Standard Specification 848.

**CHANGES TO BIDDING REQUIREMENTS:**

For the following line items, please line through the bid tab and insert the corrected quantity as annotated below:

5. No Change

**CHANGES TO CONDITIONS OF THE CONTRACT:**

6. The contract times (Section 00 52 43) will be increased 60 days. New contract times: Work will be substantially completed within 240 days, and project completed within 270 days.

**CHANGES TO SPECIFICATIONS (Volume 2- Detail Specifications):**

7. No change.

END OF ADDENDUM

--	--