

Addendum No.2
Issue Date: November 29, 2011

Project Name: Demolition of China-America Building Addition
Project No.: BD100
CRM BID #: 551
Bid Opening Thursday, December 1, 2011 4:00 pm

TO: Prospective Bidders

This addendum forms a part of the Contract Documents and modifies the original Contract Documents dated November 2011 as noted below. Acknowledge receipt of this Addendum by inserting the number and issue date of this addendum in the blank space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum No. 2 includes the following attached documents:

1. There are no attachments to this addendum

CLARIFICATIONS:

1. Owner has completed testing of roof flashing and mastic on the south wall and determined that it contains 5% chrysotile asbestos. Contractor shall be responsible for wetting and separating the masonry wall sections with the asbestos containing material (ACM) from the other building debris and providing evidence of proper disposal to the owner in the form of disposal tickets from a certified landfill.

CHANGES TO BIDDING REQUIREMENTS:

No change

ARTICLE 17 – OPENING OF BIDS

No change

CHANGES TO CONDITIONS OF THE CONTRACT:

No Change

CHANGES TO SPECIFICATIONS:

No change

CHANGES TO DRAWINGS:

No change

End of Addendum No. 2

	<p><i>City of Rocky Mount Engineering Department 331 S. Franklin St. Rocky Mount NC 27802-1180 252-972-1121</i></p>
--	---