

Addendum No. 2
Issue Date: November 9, 2010

Project Name: Sidewalk Enhancement FY 11
Project No.: CMAQ1
CRM BID #: 75991
Bid Opening November 11, 2010 2:00 PM

TO: Prospective Bidders

This addendum forms a part of the Contract Documents and modifies the original Contract Documents dated September 2010 as noted below. Acknowledge receipt of this Addendum by inserting the number and issue date of this addendum in the blank space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum No. # 1 consists of 1 page.

CLARIFICATIONS:

1. Bid item for Retrofit Existing Wheelchair Ramp (1.16, 2.16, 3.16) allows for the use of an adhesive type of raised truncated dome material and applies only to existing wheelchair ramps.
2. Bid item for Hand Rail (1.20, 2.20, 3.20) is to be constructed in accordance with CRM Standard Detail 1.14 as shown on Sheet 2 of the plans.
3. No relocation of traffic signal boxes or gas boxes is anticipated. Adjustment of traffic signal boxes and gas boxes will be considered incidental work to the project.
4. On Sheet 17 of the plans, delete the proposed sidewalk on Sunset Avenue from Sta 0+00 to Sta 11+15.
5. Bid item for Unclassified Excavation (1.03, 2.03, 3.03) is in accordance with NCDOT Standard Specification 225.
6. Bid item for Comprehensive Grading (1.05, 2.05, 3.05) is in accordance with NCDOT Standard Specification 226.

CHANGES TO BIDDING REQUIREMENTS:

For the following line items, please line through the bid tab and insert the corrected quantity as annotated below:

7. No change.

CHANGES TO CONDITIONS OF THE CONTRACT:

8. No change.

CHANGES TO SPECIFICATIONS (Volume 2- Detail Specifications):

9. No change.

END OF ADDENDUM

--	--